

Questions and Answers – LED Lighting System

Due November 22, 2022

1. In the cells, did you count as 2 or 3 fixtures since the pin night light is inside the 4' – 3 bulb fixture? **Two (2)**
2. Labor and material cost between 2', 4', and pin lights is negligible. However, the high Pod fixtures are much more expensive. Please break out the total count of those. **199 Fixtures with three (3) bulbs each**
3. Is a bid bond required? Performance Bond? **No**
4. Is the contractor responsible for coordinating and paying for recycling the bulbs? **Yes**
5. Do you want all the fixtures to have internal disconnects? **Yes**
6. Will you require certified payroll verifying Butler County's prevailing wage? **No**
7. Will the contractor have a full-time escort to locate and turn off breakers? **Yes**
8. How many cells in each pod. **48 cells in 8 pods; 40 cells in H pod; 4 cells in medical, not including booking**
9. Breakdown on type of lamps in each pod. **Please request separate spreadsheet via email.**
10. ODR & Medical what type of fixtures are existing? **Please request separate spreadsheet via email.**
11. Breakdown of type of fixtures in lobby and Office lobby. **Please request separate spreadsheet via email.**

Another spreadsheet is also available with additional "counts" which may be requested by emailing Debbie Maloney at dmaloney@butlersheriff.org.